

certificate

The applicant:

**PANESPOL SYSTEMS DE ALCOY**

Fila els verds,7 apdo323

ES-03802 ALCOY ALICANTE

is authorized to place the label " Certificate of Reaction to Fire of Construction Products " according to the report N° 2012AN0341



**aitex**

textile research institute

**CERTIFICATE OF REACTION TO FIRE OF:  
CONSTRUCTION PRODUCTS**

**N° 12AN0341**

The sample reference

**"REVESTIMIENTO PANEL"**

has been tested according to the standards UNE-EN ISO 11925-2:2011 (equivalent to EN ISO 11925-2:2010) and UNE-EN 13823:2002 (equivalent to EN 13823:2002). The classification according to standard UNE-EN 13501-1:2007+A1:2010 (equivalent to EN 13501-1:2007+A1:2010) is:

**"B-s1,d0"**

Alcoy, February 07th 2012.



**Raquel Muñoz González**  
CHIEF OF INNOVATION AREA



**Jordi Ferri Pascual**  
HEAD OF FIRE DEPARTMENT

